



United States Steel Corporation
Clairton Works
400 State Street
Clairton, PA 15025

412-003-00032
PAACH 0004200300032

ED

DEC 02 2014

3AP20

November 13, 2014

Ms. Gail Eddings
Allegheny County Health Department
Department of Air Quality
301 Thirty-Ninth Street
Pittsburgh, PA 15201


Subject: USS Reference Number: 14-0340
ACHD Reference Number: 17831
Sulfur Plant
USS Clairton Works

Dear Gail Eddings,

The attached form confirms our verbal report of the subject incident and satisfies the requirements of paragraph IV.8 of the Title V operating permit #0052 as issued on March 27th 2012.

I certify that based on the information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete. Any questions concerning this matter should be referred to Coleen M. Davis at 412-233-1015.

Sincerely,


Thomas E. Schumacher
Plant Manager
Clairton Works

CC: James W. Hagedorn (USEPA)

ED_002508A_00000115-00001

NOTICE OF OUTAGE OF EQUIPMENT
ARTICLE XXI - SECTION 2108.1

1. USS Reference Number: 14-0340
ACHD Reference Number: 17831
2. Date & Time of Breakdown: Date: 11/12/14 Time: 1029 hours
3. Company Name: U.S. Steel Corporation - USS Clairton Works
4. Specific Equipment Involved or Affected: Sulfur Plant
5. BAPC Permit Number (if applicable):
6. Location: Clairton, PA

Nature and cause of breakdown: The 600 Vacuum Carbonate Unit was switched over to the 100 Vacuum Carbonate Unit. The 100 Vacuum Carbonate Unit carbonated solution was too lean and had to be corrected for proper absorption. As a result, the 40 grain H₂S limit at the Sulfur Plant was exceeded.

8. Identification of Emissions:

- A. Type(s) (CO, NOX, SO₂, Particulates, Hydrocarbons, etc.)
Elevated H₂S in the down river gas line system, causing increased SO₂ at points of combustion.
- B. Toxic qualities of each type (including its qualities as an irritant, and its potential for causing illness, disability, or mortality). SO₂ is an eye, nose, and throat irritant.
- C. Amount of each type emitted (or likely to be emitted).
Light

9. Measures taken (or to be taken) to minimize length of breakdown and amount of emissions, including shutdown or curtailment (or why it is impossible or impractical to do so).
The problem was resolved and normal operations resumed.

10. Facility back in operation - Date: 11/12/14 Time: 1118 hours

Reviewed by Coleen M. Davis Date 11-13-14
Coleen M. Davis
Senior Environmental Control Engineer Phone: 412-233-1015